

**PERFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**

No: 526

Date: 22.06.26

It is certified that an inspection team headed by Er. Subhash Chander Sub Divisional Engineer from Water Supply & Sanitation Department Sub Division No.1 Abohar from DWSS inspected the ADHARSHILA GURUKUL GLOBAL SCHOOL Sitto Road, Azimgarh, Abohar, Distt. Fazilka. On the basis of Water Test Report (Attached) No RAWTL/2627/00069 dt 14/05/2026 of Block Water Testing Lab, Abohar and RAWTL/2627/00149 dt 22/05/2026 of Regional Advance Water Testing Lab, Phase -2, SAS Nagar, it is certified that the ADHARSHILA GURUKUL GLOBAL SCHOOL's Ground Floor has safe drinking water facilities and also maintains the hygienic sanitation condition for the students and members of staff of the Institution as per the norms prescribed by the Govt.

The above Certificate is valid for a period of One Year.

Signature of Seal.....

Name : - Subhash Chander
Sub Divisional Engineer
W/S & Sanitation Sub Div. No. 1

Designation : - Sub Divisional Engineer
Abohar

To,

**ADHARSHILA GURUKUL GLOBAL SCHOOL Sitto Road, Azimgarh,
Abohar -152116, Distt Fazilka**

Adharshila Gurukul Global School
Sitto Road, ABOHAR
Tehsil Abohar, Distt. Fazilka-152116

Note : The Certificate is to be issued by authorized officer/PHED Lab/Local Bodies

Anamika
Principal
Adharshila Gurukul Global School
Sitto Road, ABOHAR-152116 (Pb.)



BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

10

To,
Adharshila Gurukul Global School
Sitto Road abohar

No.: Abohar/2627/00069 Dated : 14/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. apwcs/26 Dated: 13/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 13/05/2026. It is request to fill the attached feedback form and send It back to Block Water Testing Laboratory, Abohar

D/A : Test Report

[Signature]

Authorized Signatory
For, Block Water Testing Laboratory
Abohar

[Signature]
Principal
Adharshila Gurukul Global School
Sitto Road, ABOHAR
Tehsil Abohar, Distt. Fazilka-152116

[Signature]
Principal
Adharshila Gurukul Global School
Sitto Road, ABOHAR-152116 (Pb.)

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road In Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT

Name & Address of Customer :
Adharshila Gurukul Global School
Abohar

Customer Reference No. No : apwcs/26 Dated : 13/05/2026
Sample Submitted by Randeep singh
Date of Sample Receipt 13/05/2026
Analysis Starting Date 13/05/2026
Analysis completion Date 14/05/2026

Discipline : Chemical Testing

Group: Water

Sample No.:
Report No.: Abohar/2627/00069
Registration no.: Abohar/REG2627/00168
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)
Sample Source: Not Mentioned(Not Mentioned)
Sample Age : Not Mentioned
Sample Check: Not Mentioned
Sample Latitude : 30.13224
Sample Longitude: 74.22667
Sample Type : Treated Water
Date of Issue : 14/05/2026
Condition of Sample : Sealed
Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Location/Depth : Adharshila Gurukul Global School Abohar(RO Water) / NA
Habitation : Not Mentioned
District : Fazilka
Longitude: 74.22667

Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
		Acceptable Limit	Permissible Limit		
pH	6.97@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
TDS	101	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
T. Alkalinity(CaCO3)	44	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
T. Hardness(CaCO3)	84	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
Calcium(Ca)	17.6	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
Chloride(Cl)	24	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

Report is issued under the following terms & Condition :

he results apply to the sample as received only.

he sample will be destroyed after retention time unless otherwise specified specially.

his report is not to be reproduce wholly or in part and can't be used as evidence in court of law.


bbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS =

an Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)

Value not available or test not performed for this parameter.

emperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Ashish Kumar

Sr. Chemist

Authorized Signatory

For, Block Water Testing Laboratory

Abohar

End of the Test Report

Adharshila Gurukul Global School

Sitio Road, Abohar

Tehsil / District, Fazilka-152116

Adharshila Gurukul Global School
Sitio Road, ABOHAR-152116 (Ph)



BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman Garh Road In Water works Near Bye pass, Abohar

bwtlabh@gmail.com

TEST REPORT

Name & Address of Customer :
Adharshila Gurukul Global School
Sitto Road abohar

Customer Reference No. No : apwcs/26 Dated : 13/05/2026
Sample Submitted by Randeep singh
Date of Sample Receipt 13/05/2026
Analysis Starting Date 13/05/2026
Analysis completion Date 14/05/2026

Discipline : Chemical Testing

Group: Water

ILR No.:

Sample Type : Water

Test Report No.: Abohar/2627/00069

Date of Issue : 14/05/2026

Registration no.: Abohar/REG2627/00169

Condition of Sample : Sealed

Collection Point: Private Submersible

Quantity/Type of Bottle: 1000 ml / Plastic Bottles

Scheme/Source: Not Mentioned(Not Mentioned)

Location/Depth : Adharshila Gurukul Global School Abohar(Ground water)(90ft) / 90 ft

Village : Not Mentioned

Habitation : Not Mentioned

Block: Not Mentioned

District : Fazilka

Latitude : 30.1358

Longitude: 74.2365

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.35@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	214	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	112	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	48	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30	250	1000	mg/l	IS 3025 (Part 32-2025) Argentometric Method


This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By




Ashish Kumar
Sr. Chemist
Authorized Signatory
For, Block Water Testing Laboratory
Abohar


Manager

End of the Test Report

Adharshila Gurukul Global School
Sitto Road, ABOHAR
Tehsil Abohar, Distt. Fazilka-152116


Principal
Adharshila Gurukul Global School
Sitto Road, ABOHAR-152116 (Ph.)